

Lower Lockyer Valley Water Supply Scheme

Parameters	Abbreviation	Value	Unit	Remarks
Announced allocation	AA			
Date of assessment	Date	1/02/2024		
Medium Priority Users	AAMP	100.0%	%	AA to increase from 91%
Useable volume	UV			
Atkinson Dam	AD	15,903	ML	
Brightview Weir	BW	349	ML	
O'Reilly's Weir	OW	533	ML	
Total useable Volume	UV	16,784	ML	
Current storage volume	CV			
Atkinson Dam	AD	18,847	ML	
Brightview Weir	BW	380	ML	
O'Reilly's Weir	OW	611	ML	
Total Storage Volume	UV	19,838	ML	
Minimum operating volume	MOV			
Atkinson Dam		2,168	ML	
Brightview Weir		6	ML	
O'Reilly's Weir		44	ML	
Total		2,218	ML	
Projected storage losses	SL			
Atkinson Dam	AD	776	ML	
Brightview Weir	BW	25	ML	
O'Reilly's Weir	OW	34	ML	
Total Storage Losses	Loss	836	ML	
Water allocations	WA			
High priority allocation	HPA	-		
Medium Priority Allocation	MPA	11,120	ML	As per 2014 amended ROP
MP Distribution Loss	Loss	1,500	ML	
Additional Parameters				
The Volume of Water Diverted	DIV(MP+HP)	1,818	ML	
Transmission and operational allowance	TOA	3,108	ML	Transmission losses