

Volume Calculation Methodology

Document number: PRO-02583

This document is the property of Seqwater. It must not be copied or reproduced in any way whatsoever without the authority of Seqwater. This document is uncontrolled when printed. An electronic database manages and stores the controlled version.

Ver No.	Description	Document Owner		Document Approver		
		Position	Approval	Position	Approval	Approval Date
5	Amended Version	Senior Service Performance Engineer	Refer to supporting Info in Rex	Team Lead Retailer Customer Experience	Refer to supporting Info in Rex	30/11/2023

Contents

- 1. Purpose 3**
- 2. Scope 3**
- 3. Procedure 3**
 - 3.1. Review Process 4
 - 3.2. Volume Estimation Calculation 4
 - 3.3. Volume Estimation Loss Rates 5
 - 3.4. Data Substitution 6
 - 3.4.1. Method 1 – Check Meter Substitution 6
 - 3.4.2. Method 2 – Historical Data Substitution..... 7
 - 3.4.3. Method 3 – Agreed Method 9
 - 3.5. Use of Meters near Bulk Supply Points 9
- 4. Definitions..... 9**
- 5. Abbreviations 10**
- 6. Roles and Responsibilities 10**
- 7. References and Related Materials 10**
- Appendix A – Alternate Methodology – Volume Estimation for Bulk Water Customers where Bulk Transport losses apply 11**
- Appendix B – Volume Estimation for Bulk Water Customers where Bulk Transport losses do not apply 13**

Version No.	Document No.	Document Owner:	Approval Date:	Document Approver:	Page:
5	PRO-02583	Senior Service Performance Engineer	30/11/2023	Team Lead Retailer Customer Experience	2 of 13

1. Purpose

The purpose of this Procedure is to provide instruction on the metering and volume calculation methodology and to meet the requirements of Chapter 4, Section 24, of the *Bulk Water Supply Code (2013)* (BWSC) under the *Water Act 2000*.

2. Scope

This Procedure applies to all workers and all employees working for or on behalf of Seqwater, unless otherwise stated.

The Procedure relates to bulk water metering and volume calculation methodology.

This Volume Calculation Methodology contains:

- The methodology for estimating or measuring the volume of bulk water supplied to Bulk Water Customers;
- Volume Estimation Loss Rates / Water Loss Rates;
- Acceptable methods of Data Substitution under Section 29 of the BWSC; and
- Requirements for the use of meters near Bulk Supply Points.

For all billing and metering activities relating to Bulk Water Meters please refer to [PRO-02338](#) – *Metering and Billing Management – Process Maps Work Instruction*.

3. Procedure

There are some off-take and bulk delivery points in the SEQ bulk supply system that do not have meters necessitating:

- Application of an estimation calculation, using existing upstream bulk meters adjusted for a derived system loss/leakage rate per retailer demand zone, to estimate the volume of water supplied to each demand zone for billing purposes. The calculation approach is specified in *Section 3.2. Volume Estimation Calculation* with individual calculation details for the following affected retailer demand zones specified as **Appendix A**:
 - City of Gold Coast;
 - Logan City Council;
 - Redland City Council;
 - Unitywater – Caboolture demand zone; and
 - Urban Utilities – Brisbane City Council zone.
- Derivation of a system loss/leakage rates applicable to the bulk supply system in each retailer demand zone where volumes are to be estimated using the alternative methodology. The method of deriving Volume Estimation Loss Rates is specified in *Section 3.3. Volume Estimation Loss Rates*.

This volume calculation methodology also sets out accepted methods for using substitute meter data in circumstances where meters are found to be faulty or temporarily inoperable, as required by Section 29 of the BWSC. The acceptable methods are specified in *Section 3.4. Data Substitution*.

Version No.	Document No.	Document Owner:	Approval Date:	Document Approver:	Page:
5	PRO-02583	Senior Service Performance Engineer	30/11/2023	Team Lead Retailer Customer Experience	3 of 13

Section 19 of the BWSC provides that metering and estimation applies to meters within the Bulk Authority's network as well as meters at a bulk supply point. *Section 3.5. Use of Meters near Bulk Supply Points* provides a process enabling Responsible Persons to use meters located near but not at Bulk Supply Points to meet their obligations under Chapter 4 of the BWSC. Responsible Person as used in this document has the same meaning as that set out in Section 20 of the BWSC (i.e. the entity who owns the infrastructure within which the meter is located).

Appendix B sets out the calculations to be used to determine volumes as required in the Bulk Water Supply Agreements for those Bulk Water Customers (or zones, as appropriate) listed below, where delivery volumes can be determined without reference to the alternate volume estimation methodology set out in *Section 3.2. Volume Estimation Calculation*:

- Unitywater – Sunshine Coast Regional Council zone;
- Urban Utilities – Ipswich City Council zone;
- Urban Utilities – Lockyer Valley Regional Council zone;
- Urban Utilities – Scenic Rim Regional Council zone; and
- Urban Utilities – Somerset Regional Council zone.

3.1. Review Process

The Volume Estimation Loss Rates / Water Loss Rates have been updated in this version (i.e. Version 5.0) of this document. Therefore, a manual adjustment will be applied to the November 2023 bulk water supply bills to account for the updated water loss estimate between 1 July 2023 and 30 November 2023. The Volume Estimation Loss Rates / Water Loss Rates stated in this version of this document will be incorporated in all invoices relating to bulk water supplied from December 2023 onwards.

3.2. Volume Estimation Calculation

The methodology set out in this section must be used to estimate the total volume of bulk water supplied to a Bulk Water Customer, where:

- Bulk Water is supplied under a Bulk Water Supply Agreement; and
- The Bulk Supply Point is unmetered; and
- The Bulk Supply Point relates to the following Bulk Water Customer (and zone where relevant):
 - City of Gold Coast
 - Logan City Council
 - Redland City Council
 - Unitywater – Caboolture demand zone
 - Urban Utilities – Brisbane City Council zone

As part of the volume calculation estimation, the following may be required:

- the use of meter data collected in relation to some, but not all, of the Bulk Water Customer's Bulk Supply Points; and/or
- the use of meter data collected in relation to another Code-Regulated Entities' bulk supply points.

However, all meters must still be used to record the volumes and flows of water through each Bulk Supply Point in accordance with Section 21 of the BWSC and such data must be provided to the Bulk Water Supply Authority in accordance with Chapter 4 of the BWSC.

Version No.	Document No.	Document Owner:	Approval Date:	Document Approver:	Page:
5	PRO-02583	Senior Service Performance Engineer	30/11/2023	Team Lead Retailer Customer Experience	4 of 13

The individual calculations to estimate the volume of water supplied to an applicable Bulk Water Customer by the Bulk Water Supply Authority is contained in Appendix A. This Appendix contains the calculation algorithms for estimation of volumes by Bulk Water Customers which need to use the alternate methodology.

For all other Bulk Water Customers, refer to their individual Bulk Water Supply Agreement for information reading how the volume of water supplied is calculated.

3.3. Volume Estimation Loss Rates

The five (5) retail demand zones in which an estimation of system losses/leakage rates is required are:

- City of Gold Coast;
- Logan City Council;
- Redland City Council;
- Unitywater – Caboolture demand zone; and
- Urban Utilities – Brisbane City Council zone.

These retail demand zones are consistent with those specified in the Operating Protocols made under Chapter 1 of the BWSC and in the Supply Information Notices made under the Bulk Water Supply Agreements. In these zones, Seqwater will calculate the water loss estimate to be deducted from bulk water bills using the following steps:

1. Using Equation 1, calculate the average water loss rate for the SEQ region over the most recent three full years of data. The data will be volume of non-revenue water and length of water mains reported by the Retailer Customer in Urban National Performance Report (NPR) of the Bureau of Meteorology (BOM) under indicators W10.1 and A2 respectively.
2. The length of Seqwater pipes within the Retailer Customer service area (which are downstream of a bulk billing meter) will be sourced from Seqwater’s geographical information system (GIS).
3. Calculate the water loss estimate by multiplying the water loss rate from step 1 by the applicable lengths of Seqwater pipe on the Retailer Customer side of the billing meters.

Equation 1: water loss rate calculation

Water loss rate (kL/km pipe/d)	=	$\frac{\text{Volume of Non-Revenue Water (kL/day)}}{\text{Total length of water supply pipe in SEQ (km)}}$
-----------------------------------	---	--

The calculation will be reviewed annually using the most recent available data and updated every three years, except when the total water loss of the entire SEQ deviates from 10% of its system input, in which case an early update will be performed. If an early update requires, Seqwater may request information from Retailer Customers based on their reported numbers in the NPR.

Version No.	Document No.	Document Owner:	Approval Date:	Document Approver:	Page:
5	PRO-02583	Senior Service Performance Engineer	30/11/2023	Team Lead Retailer Customer Experience	5 of 13

Volume Estimation Loss Rate / Water Loss Rate from 1 July 2023

The Volume Loss Rates applicable from 1 July 2023 are contained in the following table.

Supply Zone	Water Loss Rate (ML/day)
City of Gold Coast	0.272
Logan City Council	0.087
Redland City Council	0.242
Unitywater – Caboolture demand zone	0.148
Urban Utilities – Brisbane City Council zone	0.865

3.4. Data Substitution

The BWSC (Section 27) recognises that meters may, for various reasons, become temporarily or permanently inoperable or inaccurate.

In the case of Bulk Supply Points which are metered, the Responsible Person for the Bulk Supply Point must use the Alternate Methodology made by the Bulk Water Supply Authority to estimate and substitute volume data for the meter.

This section sets out meter data substitution methods which may be used to estimate volumes for a Bulk Supply Point where the meter is temporarily inoperable or inaccurate.

The accepted data substitution methods are ranked in order of preference and must be applied in this order, unless to do so is demonstrated as being not operationally feasible.

3.4.1. Method 1 – Check Meter Substitution

Metering Data obtained from another meter at the same measurement point, for the same data periods as that being substituted for, may be substituted.

- e.g. Metering installations where a check meter is installed.
- e.g. A probe or temporary measuring device may be installed and used to provide substitute measurement data until such time as the original meter is repaired. Other data substitution methods as outlined below are to be used for the period between identification of the fault and the installation of a probe or temporary measuring device.
- e.g. If a downstream meter exists and losses and/or off-take volumes between the faulty meter and the downstream meter are known or can be reasonably estimated, the downstream meter together with the intervening off-take and loss data may be used to derive an estimated volume for substitution.

This method of substitution may also include the use of data from similar meters where the flow profile of the second meter is a good match to the flow profile of the meter for which substitutions are being made. The Responsible Person must only use the check meter for data substitution if they can demonstrate to the satisfaction of the Bulk Water Supply Authority that the flow profiles of the original meter and second meter are comparable.

Version No.	Document No.	Document Owner:	Approval Date:	Document Approver:	Page:
5	PRO-02583	Senior Service Performance Engineer	30/11/2023	Team Lead Retailer Customer Experience	6 of 13

3.4.2. Method 2 – Historical Data Substitution

Where data substitution under Method 1 cannot be carried out, meter data can be substituted using the “Like Month Method” or “Average Month Method”.

2(A) “Like Month Method”

Substitutions to be made based on preferred substitute months as detailed below:

Month to be substituted	1 st preference substitute month	2 nd preference substitute month	3 rd preference substitute month	4 th preference substitute month
January	Average Month Method	Average Month Method	Average Month Method	Average Month Method
February	Average Month Method	Average Month Method	Average Month Method	Average Month Method
March	Average Month Method	Average Month Method	Average Month Method	Average Month Method
April	March**	Average Month Method	April*	March*
May	April**	Average Month Method	May*	April*
June	May**	Average Month Method	June*	May*
July	June**	Average Month Method	July*	June*
August	July**	Average Month Method	August*	July*
September	August**	Average Month Method	September*	August*
October	September**	Average Month Method	October*	September*
November	October**	Average Month Method	November*	October*
December	November**	Average Month Method	December*	January*

Where:

* occurring in the preceding calendar year as the month to be substituted.

** occurring in the same calendar year as the month to be substituted.

In applying the “Like Month Method” due consideration must be given to the level of demand restrictions in place at both the point of substitution and during the substitute month. The “Like Month Method” of substitution cannot be used in circumstances where the preferred substitute month and the month being substituted were subject to differing demand restrictions.

In circumstances where there has been no change of demand restrictions during the preceding three months the preferred substitute months marked with “**” in the table above must be used. In the case where data is to be substituted for the months of January, February and March, the “Average Month Method” is to be used.

Version No.	Document No.	Document Owner:	Approval Date:	Document Approver:	Page:
5	PRO-02583	Senior Service Performance Engineer	30/11/2023	Team Lead Retailer Customer Experience	7 of 13

2(B) “Average Month Method”

The data substitution can be made on the basis of the rolling average of the immediately preceding three months’ available meter data.

e.g. The substitution of July meter data is calculated as the weighted average of the metered volumes for the preceding April, May and June. The weighted average is based on the relative number of days occurring in each calendar month.

In circumstances where there has been a change in demand restrictions within the preceding three months and the impact on the weighted average is significant (i.e. the impact of restrictions would cause a greater than 10 per cent variation in the volume calculated using (a) in the table below compared to the volume calculated in (b) – (c) as determined by reference to the month in which the demand restriction changed) then the averaging calculations as set out in (b) – (c) are to be used.

Restriction Change Scenario		Weighted Average Calculation
a.	No change in restriction level or change not giving rise to significant impact.	Weighted Average of M₁ , M₂ and M₃ metered volumes
b.	Change in restriction level in third preceding month.	Weighted Average of M₁ and M₂ metered volumes
c.	Change in restriction level in second preceding month.	M₁ metered volume
d.	Change in restriction level during preceding month.	M₁ metered volume

Where:

M₁ = month immediately preceding month to be substituted;

M₂ = two months preceding month to be substituted; and

M₃ = three months preceding month to be substituted.

Example based on a substitution month of July

Restriction Change Scenario		Weighted Average Calculation
a.	No change in restriction level or change not giving rise to significant impact	Average of preceding April, May and June metered volumes
b.	Change in restriction level in April	Average of preceding May and June metered volumes
c.	Change in restriction level in May	June metered volume
d.	Change in restriction level during June	June metered volume

Version No.	Document No.	Document Owner:	Approval Date:	Document Approver:	Page:
5	PRO-02583	Senior Service Performance Engineer	30/11/2023	Team Lead Retailer Customer Experience	8 of 13

3.4.3. Method 3 – Agreed Method

Where data substitution is required for any period greater than three months, consideration, consultation and agreement must take place between the affected parties to resolve any abnormalities that may arise from the use of “Like Month” or “Average Month” methods over an extended period of time.

The Responsible Person must notify the Bulk Water Supply Authority in writing and seek approval to use the agreed substitution method. Such notification must include:

- the written consent of the parties to use the agreed method;
- any conditions placed upon the use of the agreed method; and
- the timeframe in which the agreed substitution method is expected to be applied.

3.5. Use of Meters near Bulk Supply Points

If a meter is located within ten (10) metres of a Bulk Supply Point and provided there are no major in-take/off-take points within that distance or change to in-take/off-take points within that distance, the meter is deemed to be at the relevant Bulk Supply Point for the purpose of the BWSC and any relevant Bulk Water Supply Agreement. If there is a change to in-take/off-take points occurring within the ten (10) metre distance from the Bulk Supply Point, the Responsible Person must notify the Bulk Water Supply Authority of the changed in-take/off-take conditions. The Bulk Water Supply Authority will determine whether meter installation can continue to be used to measure the volume at the Bulk Supply Point or whether an alternate volume estimation method will need to be used.

If a meter is deemed as the meter at a Bulk Supply Point, the Responsible Person for that Bulk Supply Point must certify that the meter complies with, as relevant, the:

- meter standard for new infrastructure (BWSC Section 22); or the
- meter standard for existing infrastructure (BWSC Section 23).

4. Definitions

Term	Definition
Bulk Supply Point	A bulk supply point nominated in a Bulk Water Supply Agreement between Seqwater and a Bulk Water Customer. <i>(i.e. the same definition as stated in the BWSC)</i>
Bulk Water Supply Authority	Seqwater <i>(for the purpose of this document)</i>
Responsible Person	The entity who owns the infrastructure within which the meter is located. <i>(i.e. the same meaning as set out in Section 20 of the BWSC)</i>

Version No.	Document No.	Document Owner:	Approval Date:	Document Approver:	Page:
5	PRO-02583	Senior Service Performance Engineer	30/11/2023	Team Lead Retailer Customer Experience	9 of 13

5. Abbreviations

Abbreviation	Description
BOM	Bureau of Meteorology
BWSC	Bulk Water Supply Code
NPR	National Performance Report
SEQ	South-east Queensland

6. Roles and Responsibilities

Role	Responsibility
Network Supply Systems team	Follow the data substitution methodology set out in this document when required.
Transactional Services team	Apply the volume calculation methodology set out in this document.
Retailer Customer Experience Team	Review, update and maintain this document.
Workers & Employees	Be aware of and comply with this Procedure.

7. References and Related Materials

Description	Location
<i>Bulk Water Supply Code (2013)</i> https://www.legislation.qld.gov.au	Internet
PRO-02338 Metering and Billing Management – Process Maps Work Instruction	REX & Waternet

Version No.	Document No.	Document Owner:	Approval Date:	Document Approver:	Page:
5	PRO-02583	Senior Service Performance Engineer	30/11/2023	Team Lead Retailer Customer Experience	10 of 13

This document is the property of Seqwater. It must not be copied or reproduced in any way whatsoever without the authority of Seqwater. This document is uncontrolled when printed. An electronic database manages and stores the controlled version.

Appendix A – Alternate Methodology – Volume Estimation for Bulk Water Customers where Bulk Transport losses apply

City of Gold Coast

Volume Estimate = Supply from Molendinar WTP, Mudgeeraba WTP, Logan City retail demand zone, SEQ (Gold Coast) Desalination Plant and Southern Regional Water Pipeline

less volume exported to Logan City retail demand zone and volumes exported through the Southern Regional Water Pipeline

less the estimate of losses in bulk transport system.

Logan City Council

Volume Estimate = Supply from South Maclean WTP, Brisbane supply zone, Gold Coast City retail demand zone and through the Eastern Pipeline Interconnector and the Southern Regional Water Pipeline

less volume exported to Gold Coast City retail demand zone and through the Eastern Pipeline Interconnector and the Southern Regional Water Pipeline

less the estimate of losses in bulk transport system.

Redland City Council

Volume Estimate = Supply from Capalaba WTP, North Stradbroke Island WTP, Amity Point WTP, Dunwich WTP, Point Lookout WTP and volumes supplied through the Eastern Pipeline Interconnector

less volumes exported through the Eastern Pipeline Interconnector

less the estimate of losses in bulk transport system.

Unitywater – Moreton Bay Regional Council zone

Volume Estimate = Supply from Bribie Island WTP, Caboolture WTP, Woodford WTP, Dayboro WTP, Petrie WTP, Banksia Beach WTP and volumes imported through the Northern Pipeline Interconnector

less volume exported through the Northern Pipeline Interconnector

less the estimate of losses in bulk transport system.

Version No.	Document No.	Document Owner:	Approval Date:	Document Approver:	Page:
5	PRO-02583	Senior Service Performance Engineer	30/11/2023	Team Lead Retailer Customer Experience	11 of 13

Urban Utilities – Brisbane City Council zone

Volume Estimate = Supply from Mt Crosby WTP, Enoggera WTP, North Pine WTP and Brisbane Aquifers, Northern Pipeline Interconnector and the Southern Regional Water Pipeline

less volumes from these supply points exported to Ipswich City, Logan City and Moreton Bay Regional Council retail demand zones and volumes exported through the Northern Pipeline Interconnector and the Southern Regional Water Pipeline

less the estimate of system losses/leakage applicable to Bulk Transport System (infrastructure formerly owned by the Bulk Water Transport Authority (LinkWater)) within the Brisbane City Council retail demand zone.

Version No.	Document No.	Document Owner:	Approval Date:	Document Approver:	Page:
5	PRO-02583	Senior Service Performance Engineer	30/11/2023	Team Lead Retailer Customer Experience	12 of 13

Appendix B – Volume Estimation for Bulk Water Customers where Bulk Transport losses do not apply

Unitywater – Sunshine Coast Regional Council zone

Volume Estimate = Supply from Image Flat WTP, Landers Shute WTP, Lake Macdonald WTP, Kenilworth WTP, Maleny WTP, Ewen Maddock WTP and volumes imported through the Northern Pipeline Interconnector

less volumes exported through the Northern Pipeline Interconnector.

Urban Utilities – Ipswich City Council zone

Volume Estimate = Supply from Mt Crosby WTP and through the Southern Regional Water Pipeline

less volume exported to Urban Utilities – Scenic Rim Regional Council zone.

Urban Utilities – Lockyer Valley Regional Council zone

Volume Estimate = Supply from Boonah-Kalbar WTP, Kooralbyn WTP, Rathdowney WTP, Helen Street WTP, Canungra WTP, Albert River WTP and Ipswich City Council distribution zone

less exports.

Urban Utilities – Somerset Regional Council zone

Volume Estimate = Supply from Kilcoy WTP, Somerset (Kilcoy) WTP, Linville WTP, Esk WTP, Somerset Dam (Esk) WTP, Toogoolawah WTP, Lowood WTP outlet to Lowood and Jimna WTP.

less exports.

Version No.	Document No.	Document Owner:	Approval Date:	Document Approver:	Page:
5	PRO-02583	Senior Service Performance Engineer	30/11/2023	Team Lead Retailer Customer Experience	13 of 13