

Lower Lockyer Valley Water Supply Scheme service targets

These service targets were agreed at the Lower Lockyer Valley Water Supply Scheme consultation forum held on 1 May 2014.

Planned shutdowns

Definition: A planned shutdown occurs when customers' supply is interrupted or restricted due to the performance of work by Seqwater that is planned in advance.

In managing planned shutdowns, Seqwater recognises that the following are important service issues:

- That you will be notified about a shutdown so that you can plan ahead;
- The timing of the shutdown should suit most customers;
- The duration of the shutdown should minimise the impact on customers while enabling Seqwater to perform maintenance on the Scheme.

Planned shutdowns – timing target

The timing of all planned shutdowns will be set following consultation with the Irrigation Consultation Forum (for a shutdown affecting a large part of the scheme) or customer groups or individuals (for shutdowns effecting small areas).

Planned shutdowns – duration target

Seqwater will complete all planned shutdowns within the period notified to customers unless later varied by agreement with the groups originally consulted, or unless circumstances arise that are beyond Seqwater's control, such as adverse weather conditions.

Planned shutdowns – notice target

For shutdowns planned to exceed 2 weeks, 8 weeks written notice will be provided to each customer affected by the shutdown. A reminder notice will be sent 2 weeks before the commencement of the shutdown.

For shutdowns planned to exceed 3 days but are less than 2 weeks, at least 2 weeks written notice by letter, fax, telephone, text, email or verbal advice will be provided to each customer affected by the shutdown unless the shutdown is opportunistic in which case less than 2 weeks' notice may be given.

For shutdowns planned to be less than 3 days, at least 5 days' notice will be provided at least verbally to each customer affected.

Each notice will state the start date, and anticipated shutdown duration.

Note: A courtesy reminder may be placed in the local newspaper one week before the planned shutdowns commence.

Unplanned shutdowns

Definition: An unplanned shutdown is an unforeseen or unplanned failure of Seqwater's water delivery infrastructure that stops or restricts the supply of water to a customer for more than 2 hours (including emergency repairs). It does not include events that are beyond Seqwater's control (e.g. power failure, or storm) and does not include interruptions to supply caused by errors in estimating water demand and releases, or the taking of water without authorisation.

Unplanned shutdown – duration targets

- Unplanned Shutdowns will be fixed so that at least partial supply can be resumed to those customers requiring water within 48 hours of Seqwater being notified of the event.
- Some events may interrupt supply greater than the above standard and are excluded from these targets. Seqwater will publish these events from time to time.

Unplanned shutdown – notice target

Seqwater will notify all affected customers requiring water verbally or by email, text, telephone, radio announcement or fax of the likely duration of the interruption to supply within 24 hours of learning of the event, or by the end of the first business day following the event, whichever is the earlier.

Unplanned shutdown – meter repairs target

Faults causing restrictions to supply will be repaired within one working day of Seqwater being notified.

Frequency of interruptions to supply

No customer will experience more than 6 planned or unplanned interruptions per water year (as defined above).

Complaints

Seqwater will provide an initial response to all complaints in writing, including email, or by telephone within 5 working days of receiving a complaint by the customer:

Seqwater will either resolve a customer's complaint, or provide a written response providing reasons why the complaint has not or cannot be resolved within 21 days of receiving the complaint.